

ATISN 26972**01a. Notifications submitted to CIW relating to legionella, water hygiene issues, or water system failures at Hafan y Waun care home**

URN	ONOTI-00231178-JLFV
Service Name	Hafan y Waun
Provider Name	Ceredigion County Council Adults & Children's Services
Date Submitted	25/07/2024
Notification Subcategory	Event which prevents or could prevent the continued delivery of the service safely to people using the service
Type of event	Legionella
Date of the event	24/07/2024
Has the issue been resolved	No
If the event is still on-going when do you expect it to be resolved	25/07/2024
Number of people using the service affected by the event	0
Summary (the story) of the circumstances surrounding the event	<p>The LA completed routine legionella testing on the 16 June 2024 which was clear.</p> <p>As part of the NHS accommodating an area of the home have retested and found the following:</p> <ul style="list-style-type: none">1 bedroom testing positive for legionella5 bedrooms testing positive for pseudomonas
Actions undertaken by the service as a result of the event	<ul style="list-style-type: none">- Additional flushing of all empty bedrooms and unused water wrapping.- Chlorination of the whole home (being complete 25.07.2024)- Re-testing of the positive outlets.- GP has been called to review any further actions required to be undertaken.
List of all referrals made to external bodies / agencies including their name and address	- Ceredigion Public Protection - Ceredigion Health and Safety - CIW
Actions undertaken by you to mitigate any immediate and on-going risks.	<ul style="list-style-type: none">- Affected rooms not being used.- Please see above

URN	ONOTI-00297897-NCZY
Service Name	Hafan y Waun
Provider Name	Ceredigion County Council Adults & Children's Services
Date Submitted	09/02/2026
Notification Subcategory	Outbreak of an infectious disease at the service
Number of staff at the service with a confirmed diagnosis	0
Number of people using the service with a possible diagnosis	0
The impact, if any, on the people using the service	The potential of the development of pneumonia.
The impact, if any, on the staff working at the service	As above
The type of infectious disease	Other notifiable disease
Please specify the disease	Legionella
Number of people using the service with a confirmed diagnosis	1
Number of staff at the service with a possible diagnosis	0
The infectious disease outbreak date	02/02/2026
Summary of the circumstances surrounding the outbreak	- 02/02/2026 confirmation of a patient of Y Bwa tested positive for legionella on admission to Bronglais General Hospital A&E
Actions taken to contain the outbreak	- 03/02/2026 re-testing of key identified rooms within Hafan y Waun. - 03/02/2026 Chlorination of key areas of the home took place. - 03/02/2026 re-testing post chlorination. - Review of flushing recording within Y Bwa. -04/02/2026 patient re-tested negative of legionella.
List of all referrals made to external bodies / agencies including their name and address	-Public Health Wales – CCC Public Protection - CIW