

ATISN 26972

05b. Legionella-related concerns, notifications, or compliance issues at other Ceredigion Council run care homes.

URN	ONOTI-00156944-JDLQ
Service Name	Hafan Deg Residential Care Home
Provider Name	Ceredigion County Council Adults & Children's Services
Date Submitted	08/11/2022
Notification Subcategory	Event which prevents or could prevent the continued delivery of the service safely to people using the service
Type of event	Presumptive Legionella
Date of the event	07/11/2022
Has the issue been resolved	No
If the event is still on-going when do you expect it to be resolved	
Number of people using the service affected by the event	1
Summary (the story) of the circumstances surrounding the event	<p>██████████ a resident was admitted to BGH ██████████</p> <p>██████████ a Presumptive Legionella was found in the urine sample carried out by BGH. And this sample has now been sent for confirmatory testing at Colindale Reference Laboratory.</p> <p>██████████.</p>
Actions undertaken by the service as a result of the event	<ul style="list-style-type: none"> - PHW have notified LA Environmental Health - A site visit has taken place by LA Environmental Health & H&S - Initial water samples have been taken today (08.11.2022) followed by full tank cleanse and disinfection with reassurance testing carried out following this work.
List of all referrals made to external bodies / agencies including their name and address	<p>PHW have noted the following - This case is classed as being presumptive due to the locally urine antigen positive result and ██████████ should be treated as a true case. It only then becomes a confirmed case with the Colindale Reference lab result.</p> <p>HSE have been notified, however this does not fall under RIDDORR (as this is a LA home). HSE have now requested site of the legionella documents.</p>
Actions undertaken by you to mitigate any immediate and on-going risks.	<p>As noted above - Initial water samples have been taken today (08.11.2022) followed by full tank cleanse and disinfection with reassurance testing carried out following this work.</p> <p>Another resident who was also admitted to hospital (██████████) has been tested for the antigen and subsequently returned as a negative (confirmation received ██████████).</p> <p>There are no other reports of symptomatic residents or staff currently.</p>